




| PRODUCT LEGEND | |
|--------------------------------------|-------------------------------------------------------------|
| 1 | INLET NIPPLE (1" MPT) |
| 2 | NUT |
| 3 | ISOLATION RING |
| 4 | COLLAR / WELD FITTING |
| 5 | STAINLESS STEEL FLEXIBLE BRAIDED HOSE (1" NOMINAL DIAMETER) |
| | (LENGTHS AVAILABLE 31" , 36" , 48" , 60" & 72") |
| 6 | COLLAR / WELD FITTING |
| 7 | NUT |
| 8 | REDUCING OUTLET (AVAILABLE 1/2" OR 3/4" FMPT) |
| 9 | CENTER BRACKET ASSEMBLY |
| 10 | SQUARE BAR (AVAILABLE IN 24" AND 48" LENGTHS) |
| 11 | END BRACKET ASSEMBLY |
| 12 | SHEET METAL SCREW |
| 13 | VIC MECHANICAL - T OUTLET STYLE 922 FIRELOCK (1" FNPT) |
| SEE VICTAULIC SUBMITTAL NUMBER 10.85 | |



NOTES:
1. REFER TO VICTAULIC SUBMITTAL 10.85 FOR ADDITIONAL DETAILS.



**BRAIDED VICFLEX FLEXIBLE
HOSE SPRINKLER ASSEMBLIES
FOR CONCEALED PENDENT SPRINKLERS**



VICTAULIC

VIRTUAL DESIGN AND
CONSTRUCTION

NOTE: Contractor to field verify all equipment configurations, nozzle locating dimensions and elevations for conformance to Victaulic layout drawing(s) PRIOR TO CUTTING PIPE. Please notify Victaulic Virtual Design and Construction Division for recommendations regarding any deviations.

All Victaulic drawings and piping engineering submittals will be based on information furnished to us and is provided solely as an aid to procurement and installation. The Victaulic Company is not responsible for design by engineer of record, erection, or operation. Liability of Victaulic Company with reference to descriptions, lengths, locations, dimensions, or any other data shown herein is limited to the amount charged by Victaulic Company for producing the drawing in question. In the event of an order, Victaulic products must be used in accordance with published specifications and Victaulic literature.

| Rev | Description | Date |
|-----|-------------|------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

| | | | |
|-------------------------|-------|------------------|------|
| Vic Details : 0312 | | DRN. BY: PP | |
| Category: | | DATE: 05/28/2020 | |
| CHK. BY: NP | DATE: | | |
| AH1_AH2_AH4_AB1_AB7_AB9 | | | REV. |