


FIGURE DOES NOT ACCURATELY REPRESENT NUMBER OF COUPLINGS THAT WILL BE PRESENT IN ASSEMBLY. ENGINEER TO SPECIFY NUMBER OF FLEXIBLE COUPLINGS REQ'D BASED ON EXPECTED MOVEMENT


NOMINAL SIZES	MOVEMENT*
3/4" - 3"	2.28"
4" - 12"	3.00"

\* MAXIMUM MOVEMENT. EXPECTED MOVEMENT (EXPANSION/CONTRACTION) TO BE SPECIFIED BY ENGINEER.



NOTE: INSTALL EXPANSION JOINT WITH GUIDES AND ANCHORS IN ACCORDANCE WITH MANUFACTURER'S INSTALLATION MANUAL

VICTAULIC STYLE 155 EXPANSION JOINT



VICTAULIC

VIRTUAL DESIGN AND CONSTRUCTION

NOTE: Contractor to field verify all equipment configurations, nozzle locating dimensions and elevations for conformance to Victaulic layout drawing(s) PRIOR TO CUTTING PIPE. Please notify Victaulic Virtual Design and Construction Division for recommendations regarding any deviations.

All Victaulic drawings and piping engineering submittals will be based on information furnished to us and is provided solely as an aid to procurement and installation. The Victaulic Company is not responsible for design by engineer of record, erection, or operation. Liability of Victaulic Company with reference to descriptions, lengths, locations, dimensions, or any other data shown herein is limited to the amount charged by Victaulic Company for producing the drawing in question. In the event of an order, Victaulic products must be used in accordance with published specifications and Victaulic literature.

Rev	Description	Date

Vic Details : 5013		DRN. BY: PP	
Category:		DATE: 05/22/2020	
CHK. BY: NP	DATE:		
VIC STYLE 155 EXP. JOINT			REV.